




**SPESIFIKASI JASA DAN MATERIAL YANG DIMINTAKAN PENAWARAN**

No	Spesifikasi barang	Jumlah	Satuan
1	CIRCUIT BREAKER, VACCUM, 3150 A, RATED BREAKING : 40 KA, RATED THERMAL STABILITY : 40 KA, RATED DYNAMIC STABILITY : 100 A, 12 KV, RATED LIGHTING IMPULSE : 75 KV, CONTROLLED VOLTAGE 110 VDC, RATED STABILITY TIME : $\geq$ 3S, MODE OF OPERATION : MOTOR SPRING ENERGY, RATED OPERATION : O-0, 3S-CO-180S,CO, REF : SIEMENS 3AH3, FUJI ELECTRIC HS4010P, 3 PHASE	2	UNIT
2	JASA PEMASANGAN VACUUM CIRCUIT BREAKER 6 KV	1	LOT
	<b>Lingkup detail pekerjaan selebihnya tertuang di dalam TOR</b>		



0